

Eaton 072735

Eaton Moeller® series PKZM0 Motor-protective circuit-breaker, 0.55 kW, 1 - 1.6 A, Screw terminals

General specifications

| | |
|-----------------------------|---|
| PRODUCT NAME | Eaton Moeller® series PKZM0 Motor-protective circuit-breaker |
| CATALOG NUMBER | 072735 |
| EAN | 4015080727354 |
| PRODUCT LENGTH/DEPTH | 76 mm |
| PRODUCT HEIGHT | 93 mm |
| PRODUCT WIDTH | 45 mm |
| PRODUCT WEIGHT | 0.28 kg |
| CERTIFICATIONS | IEC/EN 60947 UL File No.: E36332 CSA File No.: 165628 UL Category Control No.: NLRV VDE 0660 CE UL CSA Class No.: 3211-05 CSA IEC/EN 60947-4-1 CSA-C22.2 No. 60947-4-1-14 UL 60947-4-1 |
| MODEL CODE | PKZM0-1,6 |

Features & Functions

| | |
|------------------------|--|
| ACTUATOR TYPE | Turn button |
| FEATURES | Phase-failure sensitivity (according to IEC/EN 60947-4-1, VDE 0660 Part 102) |
| FUNCTIONS | Phase failure sensitive Motor protection |
| NUMBER OF POLES | Three-pole |

General information

| | |
|---|---|
| CONNECTION | Screw terminals |
| EXPLOSION SAFETY CATEGORY FOR DUST | PTB 10, ATEX 3013 Ex II (2) G [Ex eb Gb] [Ex db Gb] [Ex pxb Gb] Ex II (2) D [Ex tb Db] [Ex pxb Db] |
| LIFESPAN, ELECTRICAL | 100,000 operations |
| LIFESPAN, MECHANICAL | 100,000 Operations |
| MOUNTING POSITION | Can be snapped on to IEC/EN 60715 top-hat rail with 7.5 or 15 mm height. |
| OPERATING FREQUENCY | 40 Operations/h |
| OVERVOLTAGE CATEGORY | III |
| POLLUTION DEGREE | 3 |
| PRODUCT CATEGORY | Motor protective circuit breaker |
| PRODUCT CATEGORY | Motor protective circuit breaker |
| PROTECTION | Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274) |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) | 6000 V AC |
| SHOCK RESISTANCE | 25 g, Mechanical, according to IEC/EN 60068-2-27, Half-sinusoidal shock 10 ms |
| SUITABLE FOR | Also motors with efficiency class IE3 Branch circuit: Manual type E if used with terminal, or suitable for group installations, (UL/CSA) |
| TEMPERATURE COMPENSATION | -5 - 40 °C to IEC/EN 60947, VDE 0660 ≤ 0.25 %/K, residual error for T > 40° -25 - 55 °C, Operating range |

Climatic environmental conditions

| | |
|---|--|
| ALTITUDE | Max. 2000 m |
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
| AMBIENT OPERATING TEMPERATURE - MAX | 55 °C |
| AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN | -25 °C |
| AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX | 40 °C |
| AMBIENT STORAGE TEMPERATURE - MIN | -40 °C |
| AMBIENT STORAGE TEMPERATURE - MAX | 80 °C |
| CLIMATIC PROOFING | Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 |

Electrical rating

| | |
|---|---------|
| RATED FREQUENCY - MIN | 50 Hz |
| RATED FREQUENCY - MAX | 60 Hz |
| RATED OPERATIONAL POWER AT AC-3E, 220/230 V, 50 HZ | 0.25 kW |
| RATED OPERATIONAL POWER AT AC-3E, 380/400 V, 50 HZ | 0.55 kW |
| RATED OPERATIONAL VOLTAGE (UE) - MIN | 690 V |
| RATED OPERATIONAL VOLTAGE (UE) - MAX | 690 V |
| RATED UNINTERRUPTED CURRENT (IU) | 1.6 A |

Terminal capacities

| | |
|--------------------------------------|--|
| TERMINAL CAPACITY (SOLID) | 2 x (1 - 6) mm ² 1 x (1 - 6) mm ² |
| STRIPPING LENGTH (MAIN CABLE) | 10 mm |

Short-circuit rating

| | |
|--|---|
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICU AT 400 V AC | 150 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS AT 400 V AC | 150 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICU AT 440 V AC | 150 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS AT 440 V AC | 150 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICU AT 500 V AC | 150 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS AT 500 V AC | 150 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICU AT 690 V AC | 150 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS AT 690 V AC | 150 kA |
| SHORT-CIRCUIT CURRENT | 60 kA DC, up to 250 V DC, Main conducting paths |
| SHORT-CIRCUIT CURRENT RATING (GROUP) | 50 kA, 600 V High Fault, Fuse, SCCR (UL/CSA) with |

| | |
|--|---|
| PROTECTION) | 600 A, 600 V High Fault, Fuse, SCCR (UL/CSA) 50 kA, 600 V High Fault, CB, SCCR (UL/CSA) with 600 A, 600 V High Fault, CB, SCCR (UL/CSA) |
| SHORT-CIRCUIT CURRENT RATING (TYPE E) | Accessories required BK25/3-PKZ0-E 65 kA, 240 V, SCCR (UL/CSA) 65 kA, 480 Y/277 V, SCCR (UL/CSA) 50 kA, 600 Y/347 V, SCCR (UL/CSA) |
| SHORT-CIRCUIT RELEASE | Basic device fixed 15.5 x lu ± 20% tolerance 24.8 A, I _{rm} |

Switching capacity

| | |
|---------------------------|--|
| SWITCHING CAPACITY | 1.6 A (3 contacts in series), DC-5 up to 250V 1.6 A, AC-3 up to 690 V |
|---------------------------|--|

Trip blocks

| | |
|---|---------------------------------------|
| OVERLOAD RELEASE CURRENT SETTING - MIN | 1 A |
| OVERLOAD RELEASE CURRENT SETTING - MAX | 1.6 A |
| TRIPPING CHARACTERISTIC | Overload trigger: tripping class 10 A |

Motor rating

| | |
|--|--------|
| ASSIGNED MOTOR POWER AT 230/240 V, 60 HZ, 1-PHASE | 0.1 HP |
|--|--------|

| | |
|--|---------|
| ASSIGNED MOTOR POWER AT 460/480 V, 60 HZ, 3-PHASE | 0.75 HP |
|--|---------|

| | |
|--|---------|
| ASSIGNED MOTOR POWER AT 575/600 V, 60 HZ, 3-PHASE | 0.75 HP |
|--|---------|

Design verification

| | |
|---|--------|
| EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID | 5.36 W |
|---|--------|

| | |
|--|-----|
| HEAT DISSIPATION CAPACITY PDISS | 0 W |
|--|-----|

| | |
|--|--------|
| HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID | 1.79 W |
|--|--------|

| | |
|--|-------|
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 1.6 A |
|--|-------|

| | |
|---|-----|
| STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS | 0 W |
|---|-----|

| | |
|------------------------------------|--|
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
|------------------------------------|--|

| | |
|---|--|
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
|---|--|

| | |
|---|--|
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | Is the panel builder's responsibility. |
| 10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH | Is the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | Is the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | Is the panel builder's responsibility. |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the |

Resurse

| | |
|----------------------------|--|
| CHARACTERISTIC CURVE | eaton-manual-motor-starters-characteristic-characteristic-curve-008.eps eaton-manual-motor-starters-characteristic-characteristic-curve-006.eps |
| DECLARATIONS OF CONFORMITY | eaton-motor-protective-circuit-breaker-declaration-of-conformity-uk251167en.pdf |
| DESENE | eaton-manual-motor-starters-pkzm0-dimensions-003.eps eaton-manual-motor-starters-pkzm0-3d-drawing-004.eps eaton-manual-motor-starters-pkzm0-3d-drawing-008.eps |
| INSTRUCȚIUNI DE INSTALARE | IL03402034Z IL03407011Z.pdf |
| SCHEME ELECTRICE | eaton-manual-motor-starters-transformer-pkzm0-wiring-diagram.eps eaton-manual-motor-starters-starter-nzm-mccb-wiring-diagram.eps |

| | |
|--|--|
| | switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

DENUMIREA PROIECTULUI:

NUMĂRUL PROIECTULUI:

PREGĂTIT DE:

DATA:



Eaton Corporation plc Eaton House
30 Pembroke Road
Dublin 4, Irlanda
Eaton.com

© 2026 Eaton. Toate drepturile rezervate

Urmăriți-ne pe rețelele de socializare
pentru a obține cele mai noi
informații despre produse și
asistență.

